



Home fire safety fact sheet

Smoke Alarm Servicing Schedule

Australian Standard 1851–2012 details a servicing regime for smoke alarms in domestic dwellings.

The SA Metropolitan Fire Service (MFS) has used AS 1851-2012 to develop the schedule overleaf to record smoke alarm maintenance. Keep a copy of the completed schedule for future reference.

NB Whilst the Standard sets the minimum requirements for smoke alarm maintenance the MFS recommends that you test and clean your smoke alarms more frequently.

The MFS recommends testing them every month and cleaning them at least every six months.

For more information about smoke alarms go to MFS Home Fire & Life Safety fact sheet: "[Smoke Alarms](#)"

Home fire safety fact sheet

Six Monthly smoke Alarm Service Schedule

Six monthly	Date:		
What to check	What to do	Action taken	Comment
Smoke Alarms	Visually inspect the alarms for any condition that will impede the smoke alarm operation. e.g. excessive dust or coating of paint.		
Battery installation	Inspect the alarms to ensure that a battery is properly installed and that the 'battery missing' indicator has not operated.		
240v mains power indicator - hard-wired smoke alarms	Check that the power indicator light is illuminated.		
Alarm	Test the smoke alarm by pressing the test button to sound the alarm or engage the alarm test function in accordance with manufacturer's instructions.		
Other warning devices	Where other warning devices are used as alarm indicating devices (e.g. lights or vibrating pads) check all devices to ensure that they are in place.		

Home fire safety fact sheet

Yearly Smoke Alarm Service Schedule

Yearly	Date:		
What to check	What to do	Action taken	Comment
Smoke Alarms	Complete all the six monthly checks as per the previous chart.		
Interconnecting smoke alarms	Where smoke alarms are interconnected, test that the activation of each alarm operates the warning sound in each of the other alarms.		
Other warning devices	Where other warning devices (e.g. lights or vibrating pads) test all devices to ensure that they are working correctly.		
Smoke alarms	Clean each smoke alarm in accordance with manufacturer's instructions.		
Batteries	Check the manufacturer's requirements for battery replacement and replace the battery as required.		
Service life	Replace smoke alarms where the service life date is exceeded.		
Survey positioning	Check each alarm to ensure spacing and location requirements are in accordance with legislation i.e. to provide adequate warning to sleeping residents to allow them to evacuate in the event of a fire.		